

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:40 pm

PWS ID: UTAH22087 **Name:** SAMAK COUNTRY ESTATES WUA
Legal Contact: SAMAK COUNTRY ESTATES WUA **Rating:** Approved
JERRY BOETTCHER **Rating Date:** 04/09/1996
Address: 1176 W. 2100 SOUTH **Activity Status:** Active
SALT LAKE CITY, UT 84119
Phone Number: 435-972-1636
City Served (Area):
County: SUMMIT COUNTY
System Type: Non-community **Last Inv Update:** 03/19/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 10/29/2008 **Total Dsgn Cap:**
Population: 30 **Surveyor:** ROY DIXON **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	BOETTCHER, JERRY		801-972-1636		sales@boettcherandsons.co

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	31
			31 Total Svc Connections

Storage

Total Storage: 0 GAL **Number of Units:** 1 **Adequate Capacity:** YES

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	HYDROPNEUMATIC TANKS	Hydropneuma		Fiberglass		A	YES

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP002	SAMAK ESTATES WELL CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS002	SAMAK ESTATES WELL	Active	WL	12	75 GPM	75 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.